

Easley Memorial Gymnasium

Malh_coc03A

Treasure Valley CC

Building Type	County
Community_College	Malheur
Street	
650 College Blvd	
City	State Zip
Ontario	OR 97914
Latitude	Longitude
44.0163	116.97439
Tracking Code	Inspection Date
Miller 2004-05	8/11/2005

Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C1	3	-2	-0.5	0	0	0	-1	0	-0.5
Secondary	PC1	3.2	0	-0.5	0	0	0	-1	0	1.7
Tertiary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1


Easley Memorial Gymnasium

Final RVS Score

Final Type	Final Score
C1	-0.5

FEMA-154 Collapse Potential

Very High (100%)



- 1. Meyer-McLean Theater
- 2. Student Services
- 3. Barber Hall
- 4. Weese Building
- 5. Vo-Tech Building
- 6. CAD & Drafting Classroom
- 7. Tech Lab Building
- 8. Workforce Training Building
- 9. Oregon Trail Building
- 10. Art Building
- 11. Albertson Building
- 12. Maintenance Buildings
- 13. Elks Memorial Baseball Field
- 14. Dr. John J. Easley Memorial Gymnasium
- 15. Ore-Ida Sports Complex
- 16. Malheur Dormitory
- 17. Owyhee Dormitory
- Student Life Office



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Easley Memorial Gymnasium

Malh_coc03A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1968	1968	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
45585	2	Yes	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		Yes: Unknown	
Falling Hazards		Poor Conditions	
Other: Light Cladding			
None			
None			