

Nyssa Fire Department

City of Nyssa

Malh_fir02A

Building Type	County
Fire - City	Malheur
Street	
21 Good Avenue	
City	State Zip
Nyssa	OR 97913
Latitude	Longitude
43.87554	116.9953
Tracking Code	Inspection Date
RVS in 2006	6/30/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Nyssa Fire Department

Final RVS Score

Final Type	Final Score
C2	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Nyssa Fire Department

Malh_fir02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1938	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
17400	2	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Internal Discontinuous Diaphragm (large internal opening)	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Parapets: Unreinforced Across Front of Building		None	
None		None	
None		None	
			
E	Elevation View	S	Elevation View
			
		W	Elevation View



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries