


Malheur County Sheriff

Malheur County

Malh_pol03A

Building Type	County
EOC-Public Safety Answering P	Malheur
Street	
151 B Street West	
City	State Zip
Vale	OR 97918
Latitude	Longitude
43.98077	117.24094
Tracking Code	Inspection Date
New Building	6/30/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	0	0	0	0	-1.2	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Malheur County Sheriff

Final RVS Score

Final Type	Final Score
RM1	2.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1996	1996	1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	Yes
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
N	Primary Structural Type	N	Elevation View
			
E	Elevation View	E	Elevation View
			
E	Elevation View	S	Elevation View

