

Vale Middle School

Malh_sch12A

Vale SD 84

Building Type		County	
School		Malheur	
Street			
403 E St W			
City	State	Zip	
Vale	OR	97918	
Latitude		Longitude	
43.98045		117.24356	
Tracking Code		Inspection Date	
RVS in 2006		6/30/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Vale Middle School

Final RVS Score

Final Type


Final Score

C2

-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
121		1950	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
13035	1	Yes	Yes

Plan Irregularities	Vertical Irregularities
Out of Plane Lateral-Force-Resistance Elements	Steps in Elevation View: Single Change (Adjacent Building/Entity)
Reentrant Corners: L Shaped (Adjacent Build/Entity)	None
None	None

Falling Hazards	Poor Conditions
Parapets: General	None
Other: Brick Veneer	None
None	None



N Elevation View

N
gym Elevation View

Vale Middle School

Malh_sch12B

Vale SD 84

Building Type		County	
School		Malheur	
Street			
403 E St W			
City	State	Zip	
Vale	OR	97918	
Latitude		Longitude	
43.98032		117.24379	
Tracking Code		Inspection Date	
RVS in 2006		6/30/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Vale Middle School

Final RVS Score

Final Type

Final Score

C2

-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
121		1950	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
13035	1	No	Yes

Plan Irregularities	Vertical Irregularities
Reentrant Corners:L shaped (Adjacent Build/Entity)	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None
None	None

Falling Hazards	Poor Conditions
Other: Brick Veneer	None
None	None
None	None

