

Health Sciences (#008)

Mari_coc06A

Chemeketa CC

Building Type	County
Community_College	Marion
Street	
4000 Lancaster Dr Ne	
City	State Zip
Salem	OR 97309
Latitude	Longitude
44.97873	122.9771
Tracking Code	Inspection Date
Miller 2004-05	6/24/2004



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary	RM2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Tertiary		0	0	0	0	0	0	0	0	0


Health Sciences (#008)

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)



Salem Campus Map Legend

- 1. Bookstore and staff offices
- 2. Counseling & Career Services, Business Office, Financial Aid, Human Resources, President's Office, College Advancement, Purchasing, Enrollment Services, Student Records, Tutoring, Food Court, Disability Services, Student Life and Academic Support Services Office, Public Safety, College Access Programs, C-Store, College Support Services
- 3. General classrooms, Math lab, Theater 316 (Movie Theater)
- 4. Technical Skills classrooms, Crossroads
- 26. Classrooms A-B
- 27. Classrooms A-B
- 28. Classrooms A-F
- 29. Hospitality program offices, staff offices and classroom
- 30. Classrooms
- 31. Classroom
- 32. Classrooms A-F
- 33. Mailing, Receiving, C Copy Plus
- 34. Food Service Kitchen & Meeting Rooms
- 35. Writing Center and classrooms
- 36. Classrooms



Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Health Sciences (#008)

Mari_coc06A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1978	1978	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
71340	2	No	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		None	
Falling Hazards		Poor Conditions	
None			
None			
None			
			
S General Site		S General Site	