

## Wilmeth Trade (#004)

Mari\_coc10A

Chemeketa CC

Building Type	County	
Community_College	Marion	
Street		
4000 Lancaster Dr Ne		
City	State	Zip
Salem	OR	97309
Latitude	Longitude	
44.97962	122.97634	
Tracking Code	Inspection Date	
Miller 2004-05	6/24/2004	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card


## Wilmeth Trade (#004)

## Final RVS Score

Final Type	Final Score
RM1	0.7

## FEMA-154 Collapse Potential

High (>10%)



### Salem Campus Map Legend

- 1. Bookstore and staff offices
- 2. Counseling & Career Services, Business Office, Financial Aid, Human Resources, President's Office, College Advancement, Purchasing, Enrollment Services, Student Records, Tutoring, Food Court, Disability Services, Student Life and Academic Support Services Office, Public Safety, College Access Programs, C-Store, College Support Services
- 3. General classrooms, Math lab, Theater 316 (Movie Theater)
- 4. Technical Skills classrooms, Crossroads
- 26. Classrooms A-B
- 27. Classrooms A-B
- 28. Classrooms A-F
- 29. Hospitality program offices, staff offices and classroom
- 30. Classrooms
- 31. Classroom
- 32. Classrooms A-F
- 33. Mailing, Receiving, C Copy Plus
- 34. Food Service Kitchen & Meeting Rooms
- 35. Writing Center and classrooms
- 36. Classrooms



# OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1975	1975	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
59378	2	No	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		Yes: Unknown	
Falling Hazards		Poor Conditions	
None			
None			
None			



S General Site



S General Site