

Chemeketa CC

Building Type		County	
Community_College		Marion	
Street			
4000 Lancaster Dr Ne			
City	State	Zip	
Salem	OR	97309	
Latitude		Longitude	
44.97861		122.9781	
Tracking Code		Inspection Date	
Miller 2004-05		6/24/2004	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM2	2.8	-1	-0.5	0	2.6	0	-0.6	0	3.3
Secondary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Tertiary		0	0	0	0	0	0	0	0	0

Learning Resource (#009)

Final RVS Score

Final Type


Final Score

RM1

0.7

FEMA-154 Collapse Potential

High (>10%)



Salem Campus Map Legend

- | | |
|--|--|
| 1. Bookstore and staff offices | 26. Classrooms A-B |
| 2. Counseling & Career Services, Business Office, Financial Aid, Human Resources, President's Office, College Advancement, Purchasing, Enrollment Services, Student Records, Tutoring, Food Court, Disability Services, Student Life and Academic Support Services Office, Public Safety, College Access Programs, C-Store, College Support Services | 27. Classrooms A-B |
| 3. General classrooms, Math lab, Theater 316 (Movie Theater) | 28. Classrooms A-F |
| 4. Technical Skills classrooms, Crossroads | 29. Hospitality program offices, staff offices and classroom |
| | 30. Classrooms |
| | 31. Classroom |
| | 32. Classrooms A-F |
| | 33. Mailing, Receiving, C Copy Plus |
| | 34. Food Service Kitchen & Meeting Rooms |
| | 35. Writing Center and classrooms |
| | 36. Classrooms |



OregonGeology

 Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
 Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1999	1999	1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
74672	2	No	No

Plan Irregularities	Vertical Irregularities
Yes: Unknown	None

Falling Hazards	Poor Conditions
None	
None	
None	



S General Site



S General Site

