

City of Salem

Building Type Fire - City	County Marion	
Street 370 Trade St SE		
City Salem	State OR	Zip 97301
Latitude 44.93779	Longitude 123.04045	
Tracking Code To be Retrofit	Inspection Date 9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	0	0	0	-0.4	0	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Salem Fire Dept - Station 01

## Final RVS Score

Final Type	Final Score
C2	2.4

## FEMA-154 Collapse Potential

Low (&lt;1%)

No  
Planview  
Available



OregonGeology

# Salem Fire Dept - Station 01

Mari\_fir12A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1970	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
10080	2	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	