

Building Type	County
Fire - City	Marion
Street	
7605 3rd St	
City	State Zip
Turner	OR 97392
Latitude	Longitude
44.84512	122.95358
Tracking Code	Inspection Date
RVS in 2006	7/25/2006

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	-0.4	0	0	1.7
Secondary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4



Turner Fire Dept

Final RVS Score

Final Type	Final Score
RM1	0.9

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



Oregon Geology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1978	1978	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Torsion: Eccentric Stiffness		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	



SE General Site



NE Field Verified Year Built
1978



NW Secondary Structural Type



NW Secondary Structural Type



N General Site



NW Primary Structural Type



NW General Site



NW General Site




W Plan Irregularity Primary





SW General Site



N Other



NE Vertical Irregularity Primary

