

City of Salem

Building Type Fire - City	County Marion	
Street 1884 Lansing Ave NE		
City Salem	State OR	Zip 97303
Latitude 44.95278	Longitude 122.9974	
Tracking Code To be Retrofit	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	0	0	0	0	4.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Salem Fire Dept - Station 03

Final RVS Score

Final Type	Final Score
W1	4.4

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



OregonGeology

Salem Fire Dept - Station 03

Mari_fir16A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1970	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
4350	1	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	