

City of Salem

Building Type	County	
Fire - City	Marion	
Street		
875 Madison St NE		
City	State	Zip
Salem	OR	97303
Latitude	Longitude	
44.95485	123.02258	
Tracking Code	Inspection Date	
To be Retrofit	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	0	-0.6	0	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Salem Fire Dept - Station 02

Final RVS Score

Final Type	Final Score
RM1	2.2

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



OregonGeology

Salem Fire Dept - Station 02

Mari_fir17A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1976	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
5941	1	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	