

City of Salem

Building Type	County
Fire - City	Marion
Street	
200 Alice St SE	
City	State Zip
Salem	OR 97302
Latitude	Longitude
44.91331	123.047
Tracking Code	Inspection Date
To be Retrofit	9/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM2	2.8	0	0	0	0	0	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Salem Fire Dept - Station 04

Final RVS Score

Final Type	Final Score
RM2	2.8

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



OregonGeology

Salem Fire Dept - Station 04

Mari_fir19A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1974	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
5191	1	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	