

City of Salem

Building Type	County
Fire - City	Marion
Street	
5080 Battle Creek Rd SE	
City	State Zip
Salem	OR 97306
Latitude	Longitude
44.88185	123.01048
Tracking Code	Inspection Date
To be Retrofit	
9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	2.4	0	0	0	6.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Salem Fire Dept - Station 09

Final RVS Score

Final Type	Final Score
W1	6.8

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



OregonGeology

Salem Fire Dept - Station 09

Mari_fir20A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1982	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
3642	2	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S General Site			