

Stayton RFPD

Stayton RFPD

Mari_fir22A

Building Type Fire - RFPD	County Marion	
Street 21475 Ferry Rd		
City Stayton	State OR	Zip 97384
Latitude 44.79074	Longitude 122.6257	
Tracking Code RVS in 2006	Inspection Date 7/18/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	0	0	0	-0.6	0	0	3.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Stayton RFPD

Final RVS Score

Final Type	Final Score
S3	3.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1980	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
46500	2	No	No
Plan Irregularities		Vertical Irregularities	
None		Internal Discontinuous Diaphram (large internal opening)	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE General Site		NW General Site	
		W Primary Structural Type	

