

Building Type	County	
Fire - RFPD	Marion	
Street		
32788 NorthFork Rd SE		
City	State	Zip
Lyons	OR	97358
Latitude	Longitude	
44.81699	122.40131	
Tracking Code	Inspection Date	
RVS in 2006	7/18/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	-0.5	0	1.6	0	-0.6	0	5.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Stayton RFPD

Final RVS Score

Final Type

Final Score

W1

5.7

FEMA-154 Collapse Potential

Low (<1%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1977	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
12800	1	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SW General Site



W Building Name



SW Building Name



W Primary Structural Type



NE General Site

