

# Woodburn RFPD Broadacres Station

Woodburn RFPD

Mari\_fir26A

Building Type	County	
Fire - RFPD	Marion	
Street		
18676 Butteville Rd NE		
City	State	Zip
Woodburn	OR	97071
Latitude	Longitude	
45.18968	122.8673	
Tracking Code	Inspection Date	
RVS in 2006	8/2/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	0	0	0	0	-0.6	0	2.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Woodburn RFPD Broadacres Station

### Final RVS Score

Final Type	Final Score
S3	2.6

### FEMA-154 Collapse Potential

Low (<1%)

No  
Planview  
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Woodburn RFPD Broadacres Station

Mari\_fir26A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W	Building Name	NW	Primary Structural Type
			
N	Elevation View		
			
NW	Elevation View		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries