

Marion County Fire District 1

Marion County Fire District 1

Mari_fir28A

Building Type	County	
Fire - RFPD	Marion	
Street		
7214 Labish Center Rd		
City	State	Zip
Salem	OR	97305
Latitude	Longitude	
45.03085	122.91371	
Tracking Code	Inspection Date	
RVS in 2006	7/28/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Marion County Fire District 1

Final RVS Score

Final Type	Final Score
RM1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Marion County Fire District 1

Mari_fir28A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1968	1968	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
N Building Name		N General Site NEW FIRE STATION BUILT 2005 ACCORDING TO STAFF	
		NE Elevation View	
		SW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries