


Marion County Fire District 1 Pratum Station #3

Mari_fir30A

Marion County Fire District 1

Building Type	County	
Fire - RFPD	Marion	
Street		
8885 Sunnyview Rd NE		
City	State	Zip
Salem	OR	97305
Latitude	Longitude	
44.9596	122.87835	
Tracking Code	Inspection Date	
New Building	8/8/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	0	0	0	0	-0.6	0	2.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Marion County Fire District 1
Pratum Station #3

Final RVS Score

Final Type	Final Score
S3	2.6

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Marion County Fire District 1 Pratum Station #3

Mari_fir30A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			2000
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
None		Internal Discontinuous Diaphram (large internal opening)	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
N Primary Structural Type very nice door braces. Station could be 2000+		SW General Site	
		S Building Name	
			
SE Elevation View		NW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries