

Marion County Fire District 1

Mari_fir33A

Marion County Fire District 1

Building Type		County	
Fire - RFPD		Marion	
Street			
2218 84th Ave SE			
City	State	Zip	
Salem	OR	97301	
Latitude		Longitude	
44.90733		122.88888	
Tracking Code		Inspection Date	
RVS in 2006		8/8/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	0	0	0	0	0	0	3.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Marion County Fire District 1

Final RVS Score

Final Type

Final Score

S3

3.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No

Plan Irregularities	Vertical Irregularities
None	Internal Discontinuous Diaphragm (large internal opening)
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



W General Site



NW Elevation View



SW Elevation View



SE Elevation View