

Building Type		County	
Fire - RFPD		Marion	
Street			
661 Chemawa Rd Ne			
City	State	Zip	
Keizer	OR	97303	
Latitude		Longitude	
44.99731		123.02423	
Tracking Code		Inspection Date	
RVS in 2006		7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	0	0	0	0	0	-1	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Keizer Rire District

Final RVS Score

Final Type

Final Score

S3

2.2

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
Other: Brick Veneer	None
None	None
None	None



S Building Name
name is not on bldg A



NW General Site



W General Site



SW Building Quality
building is bolted directly to slab



NE General Site



N General Site



NE Primary Structural Type