

City of Aurora

Building Type	County	
Fire - City	Marion	
Street		
21420 Main St NE		
City	State	Zip
Aurora	OR	97002
Latitude	Longitude	
45.22968	122.75557	
Tracking Code	Inspection Date	
RVS in 2006	7/26/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Aurora Police Dept

Final RVS Score

Final Type	Final Score
W1	1.4

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built		
			1910		
Total Area (square ft)	Number of Stories	Basement	Pounding Potential		
	1	No	Yes		
Plan Irregularities		Vertical Irregularities			
Reentrant Corners: Other		Steps in Elevation View: Single Change			
None		None			
None		None			
Falling Hazards		Poor Conditions			
Other: General		Differential Settlement with Damage			
None		Poor masonry joint condition			
None		None			
	SW Building Name		NE Falling Hazard		NW General Site
	NW Plan Irregularity Primary		NE General Site		NW Poor Condition dry rot. No Foundation,
	NW Poor Condition no foundation, timber on dirt.		NE General Site		E Poor Condition





E General Site



SE General Site



E Pounding Potential



S Building Quality
Structural members



SW General Site



W Pounding Potential



SW Vertical Irregularity Primary

