

Sublimity Elementary School

North Santiam SD 29J

Mari_sch03A

Building Type		County	
School		Marion	
Street			
431 Main St			
City		State	Zip
Sublimity		OR	97385
Latitude		Longitude	
44.8304		122.78699	
Tracking Code		Inspection Date	
RVS in 2006		7/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sublimity Elementary School

Final RVS Score

Final Type

Final Score

W2

0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sublimity Elementary School

Mari_sch03A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
343		1951	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
19784	1	No	Yes

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: Single Change (Adjacent Building/Entity)
Reentrant Corners: L Shaped (Adjacent Build/Entity)	None
None	None

Falling Hazards	Poor Conditions
Other: Brick Veneer	None
Other: General	None
None	None



S Primary Structural Type




NE General Site



SE Building Name



SW General Site




NW General Site



W Falling Hazard



S Building Quality



W Falling Hazard



SW Pounding Potential



NE General Site



N Plan Irregularity Primary



NE General Site



E General Site



Sublimity Elementary School

North Santiam SD 29J

Mari_sch03B

Building Type		County	
School		Marion	
Street			
431 Main St			
City		State	Zip
Sublimity		OR	97385
Latitude		Longitude	
44.83061		122.78703	
Tracking Code		Inspection Date	
RVS in 2006		7/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	1.6	-0.8	0	0	2.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sublimity Elementary School

Final RVS Score

Final Type

Final Score

W2

2.1

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
343		1951	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
19784	1	No	Yes

Plan Irregularities	Vertical Irregularities
Reentrant Corners:L shaped (Adjacent Build/Entity)	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	Building On Hill or Sloped Site
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



NW General Site



N General Site



E Primary Structural Type