

# Jefferson Elementary School

Jefferson SD 14J

Mari\_sch05A

Building Type	County
School	Marion
Street	
615 N 2nd St	
City	State Zip
Jefferson	OR 97352
Latitude	Longitude
44.7233	123.00962
Tracking Code	Inspection Date
RVS in 2006	8/3/2006



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	0	-0.8	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Jefferson Elementary School

## Final RVS Score

Final Type	Final Score
W2	-0.5

## FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

# Jefferson Elementary School

Mari\_sch05A

Enrollment 389	Year Built (Field Verified) 1939	Year Built (Alt. Source) 1939	Est. Decade Built 1930
Total Area (square ft) 31524	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:T shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards Other: Brick Veneer Other: Smokestack None		Poor Conditions None None None	
			
SW Building Name	SW Elevation View	SW Falling Hazard	
			
SE Falling Hazard	SE Falling Hazard	SE Elevation View	
			
S Elevation View	E Basement	E Falling Hazard	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries



SW Pounding Potential



# Jefferson Elementary School

Jefferson SD 14J

Mari\_sch05B

Building Type	County
School	Marion
Street	
615 N 2nd St	
City	State Zip
Jefferson	OR 97352
Latitude	Longitude
44.72347	123.00885
Tracking Code	Inspection Date
RVS in 2006	8/3/2006



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Jefferson Elementary School

## Final RVS Score

Final Type	Final Score
C2	1.7

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# Jefferson Elementary School

Mari\_sch05B

Enrollment 389	Year Built (Field Verified) 1939	Year Built (Alt. Source) 1939	Est. Decade Built 1950
Total Area (square ft) 31524	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Torsion: Eccentric Stiffness None None		Vertical Irregularities None None None	
Falling Hazards Other: Ornamental Hazard Over Exit None None		Poor Conditions None None None	
			
S Falling Hazard	SE Primary Structural Type C2	SW Pounding Potential	
			
NE Plan Irregularity Primary	SE General Site	NE Elevation View	
			
W Elevation View	NW Pounding Potential		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Jefferson Elementary School

Jefferson SD 14J

Mari\_sch05C

Building Type School	County Marion	
Street 615 N 2nd St		
City Jefferson	State OR	Zip 97352
Latitude 44.72315	Longitude 123.00913	
Tracking Code RVS in 2006	Inspection Date 8/3/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Jefferson Elementary School

## Final RVS Score

Final Type	Final Score
C2	0.7

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

# Jefferson Elementary School

Mari\_sch05C

Enrollment 389	Year Built (Field Verified) 1939	Year Built (Alt. Source) 1939	Est. Decade Built 1960
Total Area (square ft) 31524	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards Other: Ornamental Hazard Over Exit None None		Poor Conditions None None None	
	S Elevation View		S Elevation View
NW Primary Structural Type			
			
SE Elevation View	E Elevation View		N Vertical Irregularity Primary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries