

Jefferson Middle School

Mari_sch06A

Jefferson SD 14J

Building Type		County	
School		Marion	
Street			
1328 N 2nd St			
City	State	Zip	
Jefferson	OR	97352	
Latitude		Longitude	
44.73187		123.01074	
Tracking Code		Inspection Date	
RVS in 2006		8/3/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Jefferson Middle School

Final RVS Score

Final Type

Final Score

C2

0.7

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
200	1952	1952	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
30956	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: U shaped	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
Reentrant Corners: Other	None
None	None

Falling Hazards	Poor Conditions
Other: Smokestack	None
Other: General	None
Other: Brick Veneer	None



NE Building Name



N General Site

E Primary Structural Type
C2N Falling Hazard
painted glass bloc

N Plan Irregularity Primary

S Field Verified Year Built
1952

E Elevation View



SE General Site



S Falling Hazard





SW Elevation View



Jefferson Middle School

Mari_sch06B

Jefferson SD 14J

Building Type		County	
School		Marion	
Street			
1328 N 2nd St			
City	State	Zip	
Jefferson	OR	97352	
Latitude		Longitude	
44.73174		123.01139	
Tracking Code		Inspection Date	
RVS in 2006		8/3/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Jefferson Middle School

Final RVS Score

Final Type

Final Score

C2

0.7

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
200		1952	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
30956	1	No	Yes

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SW Elevation View



SW Primary Structural Type



NW Elevation View



NW Elevation View



W Pounding Potential



NW Other

Jefferson Middle School

Mari_sch06C

Jefferson SD 14J

Building Type		County	
School		Marion	
Street			
1328 N 2nd St			
City	State	Zip	
Jefferson	OR	97352	
Latitude		Longitude	
44.73196		123.01137	
Tracking Code		Inspection Date	
RVS in 2006		8/3/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Jefferson Middle School

Final RVS Score

Final Type

Final Score

RM1

0.7

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
200		1952	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
30956	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



NW Primary Structural Type



N Elevation View



SE Elevation View



NE Plan Irregularity Primary



NW Elevation View



NW Elevation View