

North Marion Middle School

North Marion SD 15

Mari_sch09A

Building Type	County	
School	Marion	
Street		
20246 Grim Rd NE		
City	State	Zip
Aurora	OR	97002
Latitude	Longitude	
45.21338	122.79575	
Tracking Code	Inspection Date	
RVS in 2006	7/26/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	0	-0.8	0	2.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

North Marion Middle School

Final RVS Score

Final Type	Final Score
W2	2.9

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

North Marion Middle School

Mari_sch09A

Enrollment 441	Year Built (Field Verified) 1981	Year Built (Alt. Source) 1981	Est. Decade Built 1980
Total Area (square ft) 78458	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other Reentrant Corners: Other (Adjacent Build/Entity) None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
			
NW General Site	NE General Site	NW General Site	
			
NW General Site	NW Primary Structural Type	NE General Site	
			
S Field Verified Year Built 1981	N Falling Hazard	NE Pounding Potential	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

North Marion Middle School

Mari_sch09A



S General Site



SW General Site



SW Plan Irregularity Primary



W General Site



W General Site

North Marion Middle School

Mari_sch09B

North Marion SD 15

Building Type	County	
School	Marion	
Street		
20246 Grim Rd NE		
City	State	Zip
Aurora	OR	97002
Latitude	Longitude	
45.21327	122.79523	
Tracking Code	Inspection Date	
RVS in 2006	7/26/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary	PC1	2.6	0	-0.5	0	0	0	-0.6	0	1.5
Tertiary		0	0	0	0	0	0	0	0	0

North Marion Middle School

Final RVS Score

Final Type	Final Score
C2	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

North Marion Middle School

Mari_sch09B

Enrollment 441	Year Built (Field Verified) 1981	Year Built (Alt. Source) 1981	Est. Decade Built 1980
Total Area (square ft) 78458	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
			
			
			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries