

Auburn Elementary School

Salem-Keizer SD 24J

Mari_sch11A

Building Type		County	
School		Marion	
Street			
4612 Auburn Rd NE			
City	State	Zip	
Salem	OR	97301	
Latitude		Longitude	
44.93602		122.97101	
Tracking Code		Inspection Date	
Structural Engineering Report		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Auburn Elementary School

Final RVS Score

Final Type

Final Score

W2

0.5

FEMA-154 Collapse Potential

High (>10%)

No Planview Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
640		1955	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
47461	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions