

# Wright Elementary School

Salem-Keizer SD 24J

Mari\_sch18A

Building Type	County	
School	Marion	
Street		
4060 Lone Oak Rd SE		
City	State	Zip
Salem	OR	97302
Latitude	Longitude	
44.89622	123.04807	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Wright Elementary School

### Final RVS Score

Final Type	Final Score
W2	1.3

### FEMA-154 Collapse Potential

Moderate (>1%)

No  
Planview  
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Wright Elementary School

Mari\_sch18A

Enrollment 480	Year Built (Field Verified) 1960	Year Built (Alt. Source) 1960	Est. Decade Built
Total Area (square ft) 54004	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries