

Building Type	County
School	Marion
Street	
4700 Arizona Ave NE	
City	State Zip
Salem	OR 97305
Latitude	Longitude
44.96683	122.96765
Tracking Code	Inspection Date
Structural Engineering Report 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Scott Elementary School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Scott Elementary School

Mari_sch20A

Enrollment 609	Year Built (Field Verified) 1976	Year Built (Alt. Source) 1976	Est. Decade Built
Total Area (square ft) 49888	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	