

Building Type	County	
School	Marion	
Street		
530 Highland Ave NE		
City	State	Zip
Salem	OR	97303
Latitude	Longitude	
44.95952	123.02802	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	0	-0.6	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Highland Elementary School

Final RVS Score

Final Type	Final Score
URM	-0.5

FEMA-154 Collapse Potential

Very High (100%)
------------------

No  
Planview  
Available



OregonGeology

# Highland Elementary School

Mari\_sch21A

Enrollment 320	Year Built (Field Verified) 1910	Year Built (Alt. Source) 1910	Est. Decade Built
Total Area (square ft) 46128	Number of Stories 3	Basement No	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	