

Hayesville Elementary School

Salem-Keizer SD 24J

Mari_sch30A

Building Type	County	
School	Marion	
Street		
4545 Ward Dr NE		
City	State	Zip
Salem	OR	97305
Latitude	Longitude	
44.98324	122.97192	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hayesville Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Hayesville Elementary School

Mari_sch30A

Enrollment 405	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built
Total Area (square ft) 55458	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	