

Pringle Elementary School

Salem-Keizer SD 24J

Mari_sch31A

Building Type	County	
School	Marion	
Street		
5500 Reed Ln SE		
City	State	Zip
Salem	OR	97306
Latitude	Longitude	
44.87583	123.01536	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	0	0	0	3.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Pringle Elementary School

Final RVS Score

Final Type	Final Score
W2	3.7

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



OregonGeology

Pringle Elementary School

Mari_sch31A

Enrollment 481	Year Built (Field Verified) 1985	Year Built (Alt. Source) 1985	Est. Decade Built
Total Area (square ft) 50600	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
Falling Hazards		Poor Conditions	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries