

Richmond Elementary School

Salem-Keizer SD 24J

Mari_sch32A

Building Type	County	
School	Marion	
Street		
466 Richmond Ave SE		
City	State	Zip
Salem	OR	97301
Latitude	Longitude	
44.93002	123.01283	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	-1	0	-0.4	0	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Richmond Elementary School

Final RVS Score

Final Type	Final Score
C2	-0.1

FEMA-154 Collapse Potential

Very High (100%)

No
Planview
Available



OregonGeology

Richmond Elementary School

Mari_sch32A

Enrollment 375	Year Built (Field Verified) 1911	Year Built (Alt. Source) 1911	Est. Decade Built
Total Area (square ft) 45892	Number of Stories 3	Basement No	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	