

Salem Heights Elementary School

Salem-Keizer SD 24J

Mari_sch33A

Building Type	County	
School	Marion	
Street		
3495 Liberty Rd S		
City	State	Zip
Salem	OR	97302
Latitude	Longitude	
44.90525	123.05074	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	-1	0	0	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Salem Heights Elementary School

Final RVS Score

Final Type	Final Score
C2	0.3

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Salem Heights Elementary School

Mari_sch33A

Enrollment 288	Year Built (Field Verified) 1938	Year Built (Alt. Source) 1938	Est. Decade Built 1930
Total Area (square ft) 43783	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None		Vertical Irregularities None	
Falling Hazards None		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries