

Building Type School	County Marion	
Street 4512 Jones Rd S		
City Salem	State OR	Zip 97302
Latitude 44.88914	Longitude 123.04458	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	

Seismicity Zone: High

**FEMA 154 Rapid Visual Screening Score Card**

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

**Judson Middle School**

**Final RVS Score**

Final Type C2	Final Score 1.3
------------------	--------------------

**FEMA-154 Collapse Potential**

Moderate (>1%)
----------------

**No**  
**Planview**  
**Available**



# Judson Middle School

Mari\_sch39A

Enrollment 878	Year Built (Field Verified) 1957	Year Built (Alt. Source) 1957	Est. Decade Built
Total Area (square ft) 107184	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
Falling Hazards		Poor Conditions	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	