

Building Type	County	
School	Marion	
Street		
2805 Lansing Ave NE		
City	State	Zip
Salem	OR	97303
Latitude	Longitude	
44.96182	122.99874	
Tracking Code	Inspection Date	
Structural Engineering Report	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Waldo Middle School

Final RVS Score

Final Type

Final Score

C2

0.7

FEMA-154 Collapse Potential

High (>10%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
698		1957	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
108048	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions