

Building Type	County	
School	Marion	
Street		
1605 Lockhaven Dr NE		
City	State	Zip
Keizer	OR	97303
Latitude	Longitude	
45.00732	123.01123	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	0	-0.6	0	1.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Whiteaker Middle School

Final RVS Score

Final Type	Final Score
PC1	1.5

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



Whiteaker Middle School

Mari_sch43A

Enrollment 777	Year Built (Field Verified) 1966	Year Built (Alt. Source) 1966	Est. Decade Built
Total Area (square ft) 114452	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	