

Building Type	County	
School	Marion	
Street		
2373 Kuebler Rd S		
City	State	Zip
Salem	OR	97302
Latitude	Longitude	
44.887	123.0777	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	0	0	0	2.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sprague High School

Final RVS Score

Final Type	Final Score
PC1	2.1

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



Oregon Geology

Sprague High School

Mari_sch45A

Enrollment 1761	Year Built (Field Verified) 1972	Year Built (Alt. Source) 1972	Est. Decade Built
Total Area (square ft) 248734	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S General Site	S General Site	S General Site	