

Mt Angel Middle School

Mt Angel SD 91

Mari_sch52A

Building Type School	County Marion	
Street 690 E Marquam St		
City Mount Angel	State OR	Zip 97362
Latitude 45.07236	Longitude 122.79296	
Tracking Code RVS in 2006	Inspection Date 8/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mt Angel Middle School

Final RVS Score

Final Type	Final Score
RM1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Mt Angel Middle School

Mari_sch52A

Enrollment 186	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built 1960		
Total Area (square ft) 44250	Number of Stories 1	Basement	Pounding Potential Yes		
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change None None			
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None			
 S Primary Structural Type RM1		 N Elevation View		 N Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mt Angel Middle School

Mt Angel SD 91

Mari_sch52B

Building Type School	County Marion	
Street 690 E Marquam St		
City Mount Angel	State OR	Zip 97362
Latitude 45.0726	Longitude 122.79323	
Tracking Code RVS in 2006	Inspection Date 8/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mt Angel Middle School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Mt Angel Middle School

Mari_sch52B

Enrollment 186	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built 1960
Total Area (square ft) 44250	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
 W Elevation View		 SW Pounding Potential	 SW Falling Hazard

Mt Angel Middle School

Mt Angel SD 91

Building Type	County
School	Marion
Street	
690 E Marquam St	
City	State Zip
Mount Angel	OR 97362
Latitude	Longitude
45.07237	122.79364
Tracking Code	Inspection Date
RVS in 2006	8/1/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mt Angel Middle School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Mt Angel Middle School

Mari_sch52C

Enrollment 186	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built 1960
Total Area (square ft) 44250	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Non-Parallel System		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Brick Veneer		None	
None		None	
None		None	
			
NE General Site	E Field Verified Year Built 1968	NW Pounding Potential	
			
NW Elevation View	W Elevation View	W Other	
			
S Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mt Angel Middle School

Mt Angel SD 91

Mari_sch52D

Building Type School	County Marion	
Street 690 E Marquam St		
City Mount Angel	State OR	Zip 97362
Latitude 45.07224	Longitude 122.79391	
Tracking Code RVS in 2006	Inspection Date 8/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	2.4	0	-0.8	0	4.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mt Angel Middle School

Final RVS Score

Final Type	Final Score
W2	4.9

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mt Angel Middle School

Mari_sch52D

Enrollment 186	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built 1980
Total Area (square ft) 44250	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
			
NW Plan Irregularity Primary		NW General Site	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mt Angel Middle School

Mt Angel SD 91

Mari_sch52E

Building Type School	County Marion	
Street 690 E Marquam St		
City Mount Angel	State OR	Zip 97362
Latitude 45.07179	Longitude 122.79337	
Tracking Code RVS in 2006	Inspection Date 8/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	0	0	-0.8	0	2.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mt Angel Middle School

Final RVS Score

Final Type	Final Score
W2	2.5

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mt Angel Middle School

Mari_sch52E

Enrollment 186	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built 1960
Total Area (square ft) 44250	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other None None		None None None	
Falling Hazards		Poor Conditions	
Other: Brick Veneer None None		None None None	
 SE General Site		 NE Elevation View	
 NW Plan Irregularity Primary		 W Falling Hazard	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mt Angel Middle School

Mt Angel SD 91

Mari_sch52F

Building Type School	County Marion	
Street 690 E Marquam St		
City Mount Angel	State OR	Zip 97362
Latitude 45.07177	Longitude 122.79372	
Tracking Code RVS in 2006	Inspection Date 8/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	2.4	0	-0.8	0	4.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mt Angel Middle School

Final RVS Score

Final Type	Final Score
W2	4.9

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mt Angel Middle School

Mari_sch52F

Enrollment 186	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built 1980
Total Area (square ft) 44250	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
			
S Elevation View		NE Other	
			
		N Pounding Potential	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mt Angel Middle School

Mt Angel SD 91

Mari_sch52G

Building Type	County	
School	Marion	
Street		
690 E Marquam St		
City	State	Zip
Mount Angel	OR	97362
Latitude	Longitude	
45.07201	122.79369	
Tracking Code	Inspection Date	
RVS in 2006	8/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

Mt Angel Middle School

Final RVS Score

Final Type Final Score
W2 2.5

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mt Angel Middle School

Mari_sch52G

Enrollment 186	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built 1960
Total Area (square ft) 44250	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: T shaped None None		Vertical Irregularities None None None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
			
SE Other	NW Other	NW Other	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries