

John F Kennedy High School

Mt Angel SD 91

Mari_sch54A

Building Type	County	
School	Marion	
Street		
890 E Marquam St		
City	State	Zip
Mount Angel	OR	97362
Latitude	Longitude	
45.07205	122.78969	
Tracking Code	Inspection Date	
RVS in 2006	8/2/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

John F Kennedy High School

Final RVS Score

Final Type	Final Score
C2	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

John F Kennedy High School

Mari_sch54A

Enrollment 241	Year Built (Field Verified) 1958	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 56000	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
Falling Hazards Other: Ornamental Hazard Over Exit None None		Poor Conditions None None None	
			
SW Basement	SW Falling Hazard	SW Falling Hazard	
			
SW Primary Structural Type Tie rod cones	SW Elevation View	SE Other	
			
SW Elevation View	NW Vertical Irregularity Primary		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy High School

Mt Angel SD 91

Mari_sch54B

Building Type	County
School	Marion
Street	
890 E Marquam St	
City	State Zip
Mount Angel	OR 97362
Latitude	Longitude
45.0723	122.7897
Tracking Code	Inspection Date
RVS in 2006	8/2/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Tertiary		0	0	0	0	0	0	0	0	0

John F Kennedy High School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy High School

Mari_sch54B

Enrollment 241	Year Built (Field Verified) 1958	Year Built (Alt. Source) 1958	Est. Decade Built 1960
Total Area (square ft) 56000	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
Reentrant Corners: Other (Adjacent Build/Entity)		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Brick Veneer		None	
None		None	
None		None	
			
SW Primary Structural Type RM1 with some wood		NW Elevation View	
		NW Plan Irregularity Primary	
		N Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy High School

Mt Angel SD 91

Mari_sch54C

Building Type	County
School	Marion
Street	
890 E Marquam St	
City	State Zip
Mount Angel	OR 97362
Latitude	Longitude
45.07225	122.79031
Tracking Code	Inspection Date
RVS in 2006	8/2/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	0	0	0	0	-0.6	0	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

John F Kennedy High School

Final RVS Score

Final Type	Final Score
C2	2.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

John F Kennedy High School

Mari_sch54C

Enrollment 241	Year Built (Field Verified) 1958	Year Built (Alt. Source) 1958	Est. Decade Built 1950
Total Area (square ft) 56000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
NE Primary Structural Type Concrete		NW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy High School

Mt Angel SD 91

Mari_sch54D

Building Type	County	
School	Marion	
Street		
890 E Marquam St		
City	State	Zip
Mount Angel	OR	97362
Latitude	Longitude	
45.07215	122.7891	
Tracking Code	Inspection Date	
RVS in 2006	8/2/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

John F Kennedy High School

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

John F Kennedy High School

Mari_sch54D

Enrollment 241	Year Built (Field Verified) 1958	Year Built (Alt. Source) 1958	Est. Decade Built 1950
Total Area (square ft) 56000	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
Reentrant Corners: Other (Adjacent Build/Entity)		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Smokestack		Differential Settlement with Damage	
Other: General		None	
Other: Brick Veneer		None	
	SE Elevation View		NE Basement
E Elevation View			
	NE Vertical Irregularity Primary		W Falling Hazard
SW General Site			
	NW Primary Structural Type		NW Plan Irregularity Primary
S Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy High School

Mari_sch54D



NE Elevation View



NE Poor Condition



NE Poor Condition