

# Washington Elementary School

Woodburn SD 103

Mari\_sch56A

Building Type		County	
School		Marion	
Street			
777 E Lincoln St			
City	State	Zip	
Woodburn	OR	97071	
Latitude		Longitude	
45.14393		122.84691	
Tracking Code		Inspection Date	
Structural Engineering Report		9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	0	-0.8	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Washington Elementary School

## Final RVS Score

Final Type

Final Score

W2

-0.5

FEMA-154 Collapse Potential

Very High (100%)

**No  
Planview  
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
557		1916	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
54712	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions