

Building Type School	County Marion	
Street 1785 N Front St		
City Woodburn	State OR	Zip 97071
Latitude 45.15336	Longitude 122.8478	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	0	-0.6	0	1.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Woodburn High School

## Final RVS Score

Final Type	Final Score
PC1	1.5

## FEMA-154 Collapse Potential

Moderate (&gt;1%)

No  
Planview  
Available



OregonGeology

# Woodburn High School

Mari\_sch57A

Enrollment 1316	Year Built (Field Verified) 1976	Year Built (Alt. Source) 1976	Est. Decade Built
Total Area (square ft) 196964	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries