

# Stayton High School

North Santiam SD 29J

Mari\_sch59A

Building Type	County
School	Marion
Street	
757 W Locust St	
City	State Zip
Stayton	OR 97383
Latitude	Longitude
44.80318	122.80119
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Stayton High School

### Final RVS Score

Final Type	Final Score
C2	-0.1

### FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

Mari\_sch59A

Enrollment 783	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1950		
Total Area (square ft) 176771	Number of Stories 2	Basement	Pounding Potential Yes		
Plan Irregularities		Vertical Irregularities			
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes			
Reentrant Corners: Other (Adjacent Build/Entity)		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)			
None		None			
Falling Hazards		Poor Conditions			
Unreinforced Chimneys		Cracks			
Other: Brick Veneer		None			
None		None			
	SE General Site		W General Site		SW Falling Hazard
	SW General Site		W General Site		SW General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

North Santiam SD 29J

Mari\_sch59B

Building Type	County
School	Marion
Street	
757 W Locust St	
City	State Zip
Stayton	OR 97383
Latitude	Longitude
44.80328	122.80188
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	3.2	0	0	0	0	0	-1	0	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Stayton High School

## Final RVS Score

Final Type	Final Score
PC1	2.2

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

Mari\_sch59B

Enrollment 783	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1980
Total Area (square ft) 176771	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
 NE Primary Structural Type		 W Pounding Potential	
 NE General Site		 SW General Site	
 SE General Site		 W Primary Structural Type PC1	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

North Santiam SD 29J

Mari\_sch59C

Building Type	County
School	Marion
Street	
757 W Locust St	
City	State Zip
Stayton	OR 97383
Latitude	Longitude
44.80351	122.80274
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	0	0	0	0	-1	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Stayton High School

## Final RVS Score

Final Type	Final Score
S3	2.8

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

Mari\_sch59C

Enrollment 783	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1990
Total Area (square ft) 176771	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
W	General Site	N	Primary Structural Type S3



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

North Santiam SD 29J

Mari\_sch59D

Building Type School	County Marion	
Street 757 W Locust St		
City Stayton	State OR	Zip 97383
Latitude 44.80364	Longitude 122.80115	
Tracking Code RVS in 2006	Inspection Date 7/19/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	0	0	0	0	-0.6	0	4.6
Secondary	RM1	3.6	0	0	0	0	0	-1.2	0	2.4
Tertiary		0	0	0	0	0	0	0	0	0

Stayton High School

## Final RVS Score

Final Type	Final Score
RM1	2.4

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

Mari\_sch59D

Enrollment 783	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1970
Total Area (square ft) 176771	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards Other: Brick Veneer		Poor Conditions None None None	
 SE General Site		 W General Site	
 SW Primary Structural Type Wood on left, possible RM1 on right.		 N Primary Structural Type wood framed wall on inside.	
 E Falling Hazard brick veneer on front only, possible RM1.		 W General Site	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

North Santiam SD 29J

Mari\_sch59E

Building Type	County
School	Marion
Street	
757 W Locust St	
City	State Zip
Stayton	OR 97383
Latitude	Longitude
44.80383	122.80042
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	0	0	-1.2	0	3.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Stayton High School

Final RVS Score

Final Type	Final Score
W2	3.1

FEMA-154 Collapse Potential

Low (<1%)
-----------



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

Mari\_sch59E

Enrollment 783	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1970
Total Area (square ft) 176771	Number of Stories 1	Basement No	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 SE General Site		 SW General Site	
		 E Primary Structural Type	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

North Santiam SD 29J

Mari\_sch59F

Building Type School	County Marion	
Street 757 W Locust St		
City Stayton	State OR	Zip 97383
Latitude 44.80383	Longitude 122.79982	
Tracking Code RVS in 2006	Inspection Date 7/19/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary	PC1	3.2	0	-0.5	0	0	0	-1	0	1.7
Tertiary		0	0	0	0	0	0	0	0	0

Stayton High School

### Final RVS Score

Final Type	Final Score
C2	-0.1

### FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

Mari\_sch59F

Enrollment 783	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1970
Total Area (square ft) 176771	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Reentrant Corners: Other (Adjacent Build/Entity)		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W Pounding Potential		W Primary Structural Type	
		NW General Site	
			
NE General Site		NW General Site	
		NE Vertical Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

North Santiam SD 29J

Mari\_sch59G

Building Type	County
School	Marion
Street	
757 W Locust St	
City	State Zip
Stayton	OR 97383
Latitude	Longitude
44.80324	122.8001
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Stayton High School

## Final RVS Score

Final Type	Final Score
W2	0.1

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

Mari\_sch59G

Enrollment 783	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1950
Total Area (square ft) 176771	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
 NE General Site		 N Falling Hazard wall goes through the bldg. Just past the window on the right.	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

North Santiam SD 29J

Mari\_sch59H

Building Type School	County Marion	
Street 757 W Locust St		
City Stayton	State OR	Zip 97383
Latitude 44.80334	Longitude 122.80064	
Tracking Code RVS in 2006	Inspection Date 7/19/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Stayton High School

## Final RVS Score

Final Type	Final Score
W2	0.1

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

Mari\_sch59H

Enrollment 783	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1950
Total Area (square ft) 176771	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:H shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards Other: Brick Veneer Unreinforced Chimneys None		Poor Conditions None None None	
 NW General Site		 NW Primary Structural Type	 NW Falling Hazard



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

North Santiam SD 29J

Mari\_sch591

Building Type	County
School	Marion
Street	
757 W Locust St	
City	State Zip
Stayton	OR 97383
Latitude	Longitude
44.8031	122.8007
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Tertiary		0	0	0	0	0	0	0	0	0

Stayton High School

## Final RVS Score

Final Type	Final Score
C2	-0.1

## FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Stayton High School

Mari\_sch591

Enrollment 783	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1950
Total Area (square ft) 176771	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:H shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
			
NW Primary Structural Type Possible cladding panel.		W Building Name	NW General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries