

Building Type	County	
School	Marion	
Street		
1041 N Boones Ferry Rd		
City	State	Zip
Woodburn	OR	97071
Latitude	Longitude	
45.15163	122.85994	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	0	0	0	-0.6	0	-0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lincoln Elementary School

Final RVS Score

Final Type	Final Score
URM	-0.3

FEMA-154 Collapse Potential

Very High (100%)

No
Planview
Available



Lincoln Elementary School

Mari_sch64A

Enrollment 628	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built
Total Area (square ft) 60383	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries