

Building Type School	County Marion	
Street 2440 Lancaster Dr Ne		
City Salem	State OR	Zip 97305
Latitude 44.95706	Longitude 122.97949	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

McKay High School

Final RVS Score

Final Type	Final Score
RM2	0.7

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

McKay High School

Mari_sch83A

Enrollment 1836	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built
Total Area (square ft) 247176	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
Falling Hazards		Poor Conditions	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries