

Building Type School	County Marion	
Street 595 Chemawa Rd N		
City Keizer	State OR	Zip 97303
Latitude 45.00057	Longitude 123.03277	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	0	-0.8	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

McNary High School

## Final RVS Score

Final Type	Final Score
C2	0.5

## FEMA-154 Collapse Potential

High (&gt;10%)

No  
Planview  
Available



OregonGeology

# McNary High School

Mari\_sch84A

Enrollment 2035	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built
Total Area (square ft) 240200	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
Falling Hazards		Poor Conditions	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries