

Building Type	County	
School	Marion	
Street		
725 Market St Ne		
City	State	Zip
Salem	OR	97301
Latitude	Longitude	
44.95047	123.02706	
Tracking Code	Inspection Date	
Structural Engineering Report		9/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Grant Community School

Final RVS Score

Final Type	Final Score
C2	0.9

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Grant Community School

Mari_sch86A

Enrollment 482	Year Built (Field Verified) 1955	Year Built (Alt. Source) 1955	Est. Decade Built
Total Area (square ft) 39853	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	