

Building Type	County
School	Marion
Street	
410 N Water St	
City	State Zip
Silverton	OR 97381
Latitude	Longitude
45.00746	122.78432
Tracking Code	Inspection Date
Structural Engineering Report	9/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	0	0	0	0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Eugene Field Elementary School

Final RVS Score

Final Type	Final Score
URM	0.1

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Eugene Field Elementary School

Mari_sch88A

Enrollment 467	Year Built (Field Verified) 1921	Year Built (Alt. Source) 1921	Est. Decade Built 1970
Total Area (square ft) 50590	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S General Site		S General Site	