

Rosedale Elementary School

Salem-Keizer SD 24J

Mari_sch90A

Building Type		County	
School		Marion	
Street			
6974 Bates Rd S			
City	State	Zip	
Salem	OR	97306	
Latitude		Longitude	
44.85427		123.06549	
Tracking Code		Inspection Date	
Structural Engineering Report		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Rosedale Elementary School

Final RVS Score

Final Type

Final Score

W2

0.9

FEMA-154 Collapse Potential

High (>10%)

No Planview Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
166		1952	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
24632	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions