

# Hazel Green Elementary School

Salem-Keizer SD 24J

Mari\_sch91A

Building Type		County	
School		Marion	
Street			
5774 Hazelgreen Rd NE			
City	State	Zip	
Salem	OR	97305	
Latitude		Longitude	
45.00679		122.94228	
Tracking Code		Inspection Date	
Structural Engineering Report		9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hazel Green Elementary School

## Final RVS Score

Final Type

Final Score

W2

0.5

FEMA-154 Collapse Potential

High (>10%)

**No  
Planview  
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
164		1954	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
13350	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions