

|                               |                 |           |
|-------------------------------|-----------------|-----------|
| Building Type                 | County          |           |
| School                        | Marion          |           |
| Street                        |                 |           |
| 755 University Street SE      |                 |           |
| City                          | State           | Zip       |
| Salem                         | OR              | 97301     |
| Latitude                      | Longitude       |           |
| 44.93105                      | 123.03203       |           |
| Tracking Code                 | Inspection Date |           |
| Structural Engineering Report |                 | 9/15/2006 |



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

|           | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary   | C3   | 1.6         | -1         | -0.5       | -0.2     | 0          | -0.4   | 0      | 0      | -0.5      |
| Secondary |      | 0           | 0          | 0          | 0        | 0          | 0      | 0      | 0      | 0         |
| Tertiary  |      | 0           | 0          | 0          | 0        | 0          | 0      | 0      | 0      | 0         |

## Bush Elementary School

## Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| C3         | -0.5        |

## FEMA-154 Collapse Potential

Very High (100%)

No  
Planview  
Available



# Bush Elementary School

Mari\_sch96A

|                                 |                                     |                                  |                          |
|---------------------------------|-------------------------------------|----------------------------------|--------------------------|
| Enrollment<br>283               | Year Built (Field Verified)<br>1936 | Year Built (Alt. Source)<br>1936 | Est. Decade Built        |
| Total Area (square ft)<br>54770 | Number of Stories<br>2              | Basement                         | Pounding Potential<br>No |
| Plan Irregularities             |                                     | Vertical Irregularities          |                          |
|                                 |                                     |                                  |                          |
|                                 |                                     |                                  |                          |
|                                 |                                     |                                  |                          |
| Falling Hazards                 |                                     | Poor Conditions                  |                          |
|                                 |                                     |                                  |                          |
|                                 |                                     |                                  |                          |
|                                 |                                     |                                  |                          |